

Certificate of Product Approval

Certificate Number: 1139e

Issue: 01

Teletek Electronics JSC

14A Srebarna Street
Sofia
1407
Bulgaria



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

SensoIRIS WSOU IS-R
SensoIRIS BSOU IS
SensoIRIS BSST IS

Standards

EN 54-3:2001 +A1:2002 +A2:2006
EN 54-17: 2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

P Halligan
Verifier

13 October 2016
Date of Issue

13 October 2016
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 1139e Teletek Electronics JSC

Issue: 01

Certified Product	Description	LPCB Ref.No.
SensolRIS WSOU IS-R	Intelligent Analogue Addressable Fire Alarm Type A Indoor Sounder with built-in Short Circuit Isolator Module Notes: 1. Approved to Type A Indoor only. 2. Meets the requirements of EN 54-3 and approved at the following tone: - Tone 27, 2400Hz – 2900Hz @ 3Hz high volume only	1139e/01
SensolRIS BSOU IS	Intelligent Analogue Addressable Fire Alarm Type A Base Sounder with built-in Short Circuit Isolator Module Notes: 1. Approved to Type A Indoor only. 2. Meets the requirements of EN 54-3 and approved at the following tone: - Tone 27, 2400Hz – 2900Hz @ 3Hz high volume only	1139e/02
SensolRIS BSST IS	Intelligent Analogue Addressable Fire Alarm Type A Base Sounder Strobe/Flash with built-in Short Circuit Isolator Module Notes: 1. Approved to Type A Indoor only. 2. Meets the requirements of EN 54-3 and approved at the following tone: - Tone 27, 2400Hz – 2900Hz @ 3Hz high volume only	1139e/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan
Verifier

13 October 2016
Date of Issue

13 October 2016
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com


